


FLOOR PLAN – FIRE PROTECTION

SCALE: 1/8" = 1'-0"




ATTIC PLAN – FIRE PROTECTION

SCALE: 1/8" = 1'-0"

PLAN NOTES


- 1 SEE NFPA 13R WET PIPE SPRINKLER RISER DETAIL ON SHEET FP001.
- 2 EXTEND UNDERGROUND TO FIRE DEPARTMENT CONNECTION. SEE SITE PLAN.
- 3 WET PIPE FIRE SUPPRESSION SERVICE TO OCCUPIED SPACE.
- 4 EXTEND WET PIPE FIRE SUPPRESSION TO ENCLOSED MECHANICAL SPACE IN ATTIC.
- 5 2" COMBINED DOMESTIC WATER & FIRE PROTECTION SERVICE. SEE CIVIL DRAWINGS FOR CONTINUATION.
- 6 SEE DETAIL A4 ON SHEET A8.01.
- 7 RUN SPRINKLER PIPE IN JOIST SPACE. INSTALL IN ACCORDANCE WITH NFPA 135, FIGURE A5.3.2.
- 8 SEE DETAILS A2 & A3 ON SHEET A8.01.
- 9 SEE DETAIL B1 ON SHEET A8.01.




HUDSON + ASSOCIATES
ARCHITECTS
150 WEST QUEENS WAY SUITE 201
(757) 722-1844
HAMPTON, VA 23069



BROGDEN LANE
ICF/MR HOME
FOR HNN C6B



2712 SOUTHERN BLVD., SUITE 201
VIRGINIA BEACH, VIRGINIA 23462
PHONE: 757.263.5851
FAX: 757.263.6419
EMAIL: information@pmedg.com



FLOOR PLAN -
FIRE PROTECTION

REVISION DATE
9/17/08

JOB NUMBER 0704
FP1.01